



400 Main Street, Ashland, MA 01721 USA
508.881.2000 | kiddefiresystems.com

BULLETIN

#2021-09K

Date: February 11th, 2021
To: All Engineered Systems Distributors
From: Kidde Fire Systems Product Management
Subject: AEGIS™-XLT Spurt Feature Update

AEGIS™-XLT Feature Update on Spurt and Non-Latching Manual Release Functions

IMPORTANT PRODUCT INFORMATION – PLEASE IMMEDIATELY SHARE WITH SALES, DESIGN & PURCHASING

Kidde Fire Systems would like to make all customers aware that the AEGIS™-XLT Conventional Control Units have two features that operate differently than on the legacy Chemetron® MICRO XLT Ip Conventional Control Units.

For AEGIS™-XLT Conventional Control Units, the following two features are not compatible with one another and can not be used together simultaneously on the same control unit:

Feature 1 – Spurt

Feature 2 – Non-Latching Manual Release

Should your application (such as LP-CO2, water mist or deluge) require the use of both Spurt and Non-Latching Manual Release features simultaneously on the same control unit, please use the ARIES®-SLX Single Loop Intelligent Control Unit which supports the simultaneous use of both features.

Questions or Concerns

If you have any questions or concerns, please contact us at:

Sales	Domestic , International
Product Management:	(508) 881-2000
Customer Service:	(508) 881-2000 domestic_cs@carrier.com international_cs@carrier.com
Applications Engineering	(866) 287-2531 kidde_applications@carrier.com
Technical Support:	(866) 287-2531 kidde_techsupport@carrier.com

