



Detection, Fire Alarm and Signaling Equipment | Notification Appliances | **Notification Appliances**

Series MBS-G6 or -G10-24, MBS-G6 or -G10-12

Product Description

Motor Bell Strobe. Series MBS-G6 or -G10-24 (-LS, -MS, -IS, -HWP or -LSM Series Strobes for 20-31 V dc. Series MBS-G6 or -G10 -12 (-LS or -LSM Series Strobes) for 10.5-15.6 V dc.

Details

Category	Notification Appliances
Certification Type	FM Approved
Listing Country	United States of America

Company

Cooper Notification Inc
273 Branchport Ave, Long Branch , New Jersey 07740
United States of America
<http://cooper-safety.com>