

CO₂ Component Description



A UTC Fire & Security Company

Pressure Operated Siren


Effective: February 2007

K-81-5220

P/N: 981574

NOMINAL FLOW RATE AT 70 DEGREES

CARBON DIOXIDE	20.4 LBS/MIN
HALON 1301	21.2 LBS/MIN



MATERIALS

BODY: BRONZE

ROTOR: BRASS

NOZZLE AND FILTER: MONEL

HOOD: STEEL

FINISH: RED PAINT

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, INC., Ashland, MA 01721. Telephone: (508) 881-2000.