

Kidde Fire Protection Inert Gas System (400 Series)



Component Description: Distance Pipe, Cylinder Racking Components

Effective: August 2018
KDS 03-8331-0XX0 Rev AA

FEATURES


- For Approvals, see the "COMPATIBILITY" table.
- REACH and RoHS compliant

DESCRIPTION

Use the distance pipe as a spacer when the front row of a cylinder rack has less cylinders than the rear row of the rack. Distance Pipes are only used on multi-row systems.

ORDERING INFORMATION

Part Number	Description
03-8331-0000	Distance Pipe 3/4" + Washers 80L
03-8331-0140	Distance Pipe 3/4" + Washers 140L



COMPATIBILITY

Series	DIOM P/N	Approvals*
Kidde Fire Protection IGS	06-237518-001	LPCB
* For additional listings, contact Kidde Fire Protection		

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The fire suppression system design, installation, maintenance, service and troubleshooting must be performed by trained, authorized Kidde Fire Protection distributors for the product to work correctly. If you need more information on this product, or if you have a particular problem or question, contact Kidde Fire Protection, Buckinghamshire, HP14 3SX, United Kingdom. Telephone: +44 (0)1494 480410.

©2018 Kidde-Fenwal, Inc.

KP-38-3580

Kidde Fire Protection
1st Floor, Stokenchurch House,
Oxford Road, Stokenchurch,
Buckinghamshire,
HP14 3SX, United Kingdom
Tel: +44 (0)1494 480410
www.kfp.co.uk